

GENERAL ALERT



Electrical Safety

The following precautions must be observed by all employees and contractors performing work for Roper Gulf Regional Council:

- Only licenced and qualified persons are to perform electrical work.
- All areas for electrical work must be isolated at the switchboard and tagged prior to proceeding with any work.
- Working on live electrical equipment must only be considered for testing and commissioning, and then only when a documented risk assessment has been undertaken by the workgroup and approved by Roper Gulf.
- Residual Current Devices are to be used and must be tested before being brought to a Roper Gulf work site.
- All electrical leads, tools and equipment must be tested & tagged in accordance with AS3760.
- Visually inspect electrical leads, tools and equipment for damage before each use.

Date of Issue: 4th July 2014

Name of Authoriser: Marc Gardner

Position of Authoriser: Director Contracts and Technical Services

Do not remove from Notice Boards before 31 August 2014